

博覧会会場におけるガス使用見込み量

年	月	ガスデマンド m3/h		①CGS m3	②冷水製造 m3	③迎賓館 m3	必要ガス量 m3
		中圧A	低圧	中圧A	中圧A	低圧	① + ② + ③
24	9	200			12,000		12,000
	10	200			12,000		12,000
	11	200			12,000		12,000
	12	200			12,000		12,000
25	1	200			12,000		12,000
	2	200			12,000		12,000
	3	200			12,000		12,000
	4	600	18	39,600	20,400	600	60,600
	5	1,000	30	66,000	21,000	1,000	88,000
	6	1,200	30	64,000	128,000	1,000	193,000
	7	1,400	30	66,000	226,000	1,000	293,000
	8	1,400	30	66,000	223,000	1,000	290,000
	9	1,200	30	64,000	104,000	1,000	169,000
	10	600	13	28,000	41,600	420	70,020
	11	300			20,880		20,880
	12	300			20,880		20,880
計				393,600	889,760	6,020	1,289,380